

07 80 00 – Fire and Smoke Protection

1. General

- A. The Consultant must specify an FM Global Approved, Class 1-60 or Class 1-90 roof assembly on all University buildings. The assembly shall include both the deck and the insulation systems. Any materials used shall not contain asbestos. Location of fireproofing shall conform with standards relating to fire-rated assemblies.