

## 10 21 13.19 – Plastic Toilet Compartments

### 1. General

- A. Toilet compartments shall meet ADA standards. Partitions and doors shall be made of solid HDPE or phenolic material and shall be anchored to the floor or ceiling mounted. Each shall be provided with overhead bracing and an approved head rail. Side panels and door panels shall be 1 inch thick minimum. Stainless steel plinths (movable for cleaning) on pilasters shall be provided. Panels shall be mounted to the wall with continuous aluminum or chromium-plated channels fastened with tamper-proof screws. Coat hooks shall be provided on compartment doors. In accessible toilet compartments, coat hook should meet ADA standards for reach ranges.