

Proposed Combined Heat & Power (CHP) Plant - Emissions Calculations

September 23, 2016



**Duke University
Facilities Management Department**

Proposed Combined Heat & Power – Emissions Calculations

Duke University is a large and diverse campus with energy intensive research and medical facilities that require the highest level of dependability from its utility systems. The University has also committed to become a carbon neutral campus by 2024 and has developed a Climate Action Plan (CAP) to meet this ambitious goal. Much progress has been made since Duke made the commitment in 2007 to become climate neutral.

Duke is considering a proposal to partner with Duke Energy on a Combined Heat and Power (CHP) plant on campus to further reduce carbon emissions on campus and in North Carolina as well as increase the reliability of the University system. The following are estimates of the impact the CHP would have on emissions.


Emissions Impact from CHP

There are two main impacts regarding the emissions from the CHP:

- 1) Impact to Duke University's CAP emissions and
- 2) Impact to emissions in North Carolina.

University CAP Emissions Impact

Since the steam and hot water is generated from waste heat, it is considered carbon-free. The amount of the heat from the CHP is enough to reduce the annual production from the University's steam plant by 50%, thus reducing the amount of natural gas burned at the plants. This will result in an **18% reduction** in CAP emission for the campus.



Proposed Combined Heat & Power – Emissions Calculations


Impact to Emissions in North Carolina

In order to evaluate the impact to emissions to North Carolina, the total source energy emissions must be taken into consideration. Total source energy emissions is defined as the emissions from both Duke Energy's production of 20MW of power plus Duke University's production of steam equivalent to the CHP heat output and compared to the CHP's emissions. The generation is an offset since this electricity generation is not for any new demand, so there will be a corresponding reduction at one or more of Duke Energy's current generation stations. The most likely scenario is that a gas-fired or coal-fired power plant would need to produce 20MW less as a result of the CHP. Both Duke Energy and Duke University Facilities Management Department (FMD) staff have evaluated the impact. In addition, FMD requested the calculations be reviewed by Nicholas School faculty and engaged an engineering consultant, Affiliated Engineers Inc. (AEI), to perform independent emissions calculations under several scenarios to determine the impact. AEI was also the consultant that assisted with developing the original CAP.

Emissions Estimates were performed or reviewed by:

- Duke FMD: Estimated a 26% reduction
- Duke Faculty: Timothy L. Johnson, Associate Professor of the Practice in Energy & the Environment, EE Program Chair: Reviewed and concurs with FMD's estimate
- Duke Energy Carolinas: Estimated a 30% reduction
- Affiliated Engineers Inc., engineering consultant firm estimated 3 scenarios:
 1. Compared to Duke Energy's entire generation mix – a 23% reduction
 2. Compared to Duke Energy's natural gas generation mix – a 39% reduction
 3. Compared to Duke Energy's fossil fuel generation mix – a 49% reduction

Graphical Representation of AEI's Scenario #1



Proposed Combined Heat & Power – Emissions Calculations

AEI Scenario #1 – All Duke Energy Generation

Based on First Year Full Operation				Assumptions
Electrical Output (net)	20,213 kw	X 8350 hrs/yr	= 168,777,506 kwh/yr	Predicted runtime at full load
Thermal Output	87.1 mmbtu	X 8350 hrs/yr	= 727,123 mmbtu/yr	Delivered steam and hot water
Generator Efficiency			35.9%	Turbine Higher Heating Value efficiency
NG Input	191.94 mmbtu	X 8350 hrs/yr	= 1,602,723 mmbtu/yr	Predicted turbine fuel consumption
Business as Usual (BAU) Emissions				
Electrical Generation	168,777,506 kwh/yr	X 0.77 lb/kwh	= 59,072 MTCO _{2e}	Duke Energy all generation sources
Elec. Transmission Losses	15,189,976 kwh/yr	X 0.77 lb/kwh	= 5,316 MTCO _{2e}	Reported 9% grid losses to deliver power
DU Steam Generation	727,123 mmbtu/yr	X 117 lb/mmbtu	= 46,035 MTCO _{2e}	Equivalent DU steam plant production
BAU TOTAL			110,424 MTCO_{2e}	
CHP Emissions				
Turbine	1,602,723 mmbtu/yr	X 117 lb/mmbtu	= 85,236 MTCO_{2e}	Total useful energy output
NET SAVINGS			25,188 MTCO_{2e}	Difference between BAU & CHP
% Savings vs BAU			23% reduction	

AEI Scenario #2 – Only Duke Energy’s natural gas generation mix

Based on First Year Full Operation				Assumptions
Electrical Output (net)	20,213 kw	X 8350 hrs/yr	= 168,777,506 kwh/yr	Predicted runtime at full load
Thermal Output	87.1 mmbtu	X 8350 hrs/yr	= 727,123 mmbtu/yr	Delivered steam and hot water
Generator Efficiency			35.9%	Turbine Higher Heating Value efficiency
NG Input	191.94 mmbtu	X 8350 hrs/yr	= 1,602,723 mmbtu/yr	Predicted turbine fuel consumption
Business as Usual (BAU) Emissions				
Electrical Generation	168,777,506 kwh/yr	X 1.14 lb/kwh	= 87,457 MTCO _{2e}	Offset only 35% efficient NG plants (1.14 lbs/kwh)
Elec. Transmission Losses	15,189,976 kwh/yr	X 0.77 lb/kwh	= 5,316 MTCO _{2e}	Reported 9% grid losses to deliver power
DU Steam Generation	727,123 mmbtu/yr	X 117 lb/mmbtu	= 46,035 MTCO _{2e}	Equivalent DU steam plant production
BAU TOTAL			138,809 MTCO_{2e}	
CHP Emissions				
Turbine	1,602,723 mmbtu/yr	X 117 lb/mmbtu	= 85,236 MTCO_{2e}	Total useful energy output
NET SAVINGS			53,574 MTCO_{2e}	Difference between BAU & CHP
% Savings vs BAU			39% reduction	


AEI Scenario #3 – Only Duke Energy’s natural gas generation mix

Based on First Year Full Operation				Assumptions
Electrical Output (net)	20,213 kw	X 8350 hrs/yr	= 168,777,506 kwh/yr	Predicted runtime at full load
Thermal Output	87.1 mmbtu	X 8350 hrs/yr	= 727,123 mmbtu/yr	Delivered steam and hot water
Generator Efficiency			35.9%	Turbine Higher Heating Value efficiency
NG Input	191.94 mmbtu	X 8350 hrs/yr	= 1,602,723 mmbtu/yr	Predicted turbine fuel consumption
Business as Usual (BAU) Emissions				
Electrical Generation	168,777,506 kwh/yr	X 1.52 lb/kwh	= 116,226 MTCO _{2e}	Duke Energy fossil fuel plants (coal and NG)
Elec. Transmission Losses	15,189,976 kwh/yr	X 0.77 lb/kwh	= 5,316 MTCO _{2e}	Reported 9% grid losses to deliver power
DU Steam Generation	727,123 mmbtu/yr	X 117 lb/mmbtu	= 46,035 MTCO _{2e}	Equivalent DU steam plant production
BAU TOTAL			167,578 MTCO_{2e}	
CHP Emissions				
Turbine	1,602,723 mmbtu/yr	X 117 lb/mmbtu	= 85,236 MTCO_{2e}	Total useful energy output
NET SAVINGS			82,342 MTCO_{2e}	Difference between BAU & CHP
% Savings vs BAU			49% reduction	

Proposed Combined Heat & Power – Emissions Calculations

Since the most likely scenario for the generation offset from the CHP will be a Duke Energy fossil fuel plant(s), total source energy emissions are expected to be **reduced by 39% - 49%** versus separately produced power and steam.

Even when comparing the CHP to Duke Energy’s published anticipated emissions (which include projections for new nuclear generation) over the next 20 years, Duke Energy is not expected to have fleet emissions factors lower than the proposed CHP.



END